

DEKLARACJA ZGODNOŚCI

Producent: SATEL Sp. z o.o.
ul. Budowlanych 66
80-298 Gdańsk
tel. (+48 58) 320-94-00
fax. (+48 58) 320-94-01

deklaruje na swoją wyłączną odpowiedzialność że

produkt: AQUA PLUS – cyfrowa czujka ruchu

Opis produktu: Cyfrowa pasywna czujka podczerwieni z podwójnym pyroelementem wykorzystywana do detekcji ruchu w systemach sygnalizacji włamania i napadu.

spełnia wymagania zasadnicze zawarte w Dyrektywach UE:

EMC: 2014/30/EU



W procedurze oceny zgodności wykorzystane zostały następujące normy zharmonizowane:

EMC/Odporność EN 50130-4:2011, EN 61000-6-1:2007

EMC/Emisje EN 50032:2015, EN 61000-6-3:2007

Gdańsk, Polska, 14.02.2018

A handwritten signature in blue ink, appearing to read 'Mikołaj Liskin'.

Mikołaj LISKIN
Kierownik Działu Badań



TREZOR TEST s.r.o.
Na Vršku 67, Klecany

CERTIFICATION BODY NO. 3025
ACCREDITED BY
THE CZECH ACCREDITATION INSTITUTE

CERTIFICATE OF CONFORMITY

Registration number: TT – 182/2016
for
SATEL Sp. z o.o.
Budowlanych 66, 80-298 Gdańsk, Poland

PRODUCT
(identification):

PIR detector
type AQUA Plus (AQUA Pet)
and its configuration according to appendix no. 1
Producer: SATEL Sp. z o.o.
Budowlanych 66, 80-298 Gdańsk, Poland
CZ-CPA 27.90.11

CLASSIFICATION
(of the product):

The product in accordance with the certification scheme 5 ISO/IEC 17067:2013
and in conformity with requirements of

EN 50131-1:2006, EN 50131-2-2:2008

Security Grade 2
Environmental Class II

The certificate is issued on the basis of the certification report no. CE 35/2016 within the accreditation according to the certificate no. 709/2015 of 19. October 2015 issued by the Czech Accreditation Institute.

Chairman of the Certification board
CO No. 3025
Ing. Oldřich UHLÍŘ

Deputy chairman of the Certification board
CO No. 3025
Ing. Daniela ČÍŽKOVÁ

Date of issue: 05. 05. 2016

Date effective: 05. 05. 2016
Valid till: 05. 05. 2019

This certificate can be used and duplicated only unchanged and with all enclosures.

**CERTIFICATION BODY No. 3025 FOR CERTIFICATION
OF PRODUCTS TREZOR TEST s.r.o.**

Appendix 1 is an integral part of
the certificate no. TT-182/2016
that is valid till May 5, 2019
Page: 1 / 1

PIR detector
type AQUA Plus (AQUA Pet)
in configuration:
INTEGRA 64 Plus The control panel
INT-KLCDR Keyboard
INT-S Block keyboard
GRAPHITE Digital motion detector
GRAPHITE Pet Digital motion detector

Klecany, May 5, 2016